

WW INOP
Dataset 09.07.2017 1315hrs

| | | |
|---------------|-------------------------|------------------------|
| county | vvICurrentStatus | facilityName |
| ARANSAS | DES | ALCOA POINT COMF... |
| Brazoria | INOP | ARANSAS NATIONAL ... |
| CALHOUN | NonOp | ARCHDIOCESE OF GA... |
| Fort Bend | | BEACH ROAD MUD - ... |
| Galveston | | BLOOMINGTON ISD - ... |
| Hardin | | BLUE RIDGE WEST M... |
| Harris | | BOLIVAR UTILITY SER... |

Total 40

| vvICurrentStatus | ID | facilityName | comments_Second | county | Expr1 | Expr2 |
|------------------|----------|---|---|-----------|---------------|--------------|
| DES | 12936001 | BOLIVAR UTILITY SERVICES LLC - CRYSTAL PALACE WWTP | Crystal Palace completely destroyed, no access | Galveston | Chris Makin | 409-684-9941 |
| INOP | 12128001 | HORSEPEN BAYOU MUD - WILLIAM H PORTER WWTP | Yes - all four blowers continued to run pumping creek water thru the plant. Once we arrived we shut off two of the pumps.Parts of the system is underwater however all lift stations are okay, | Harris | Susan Young | 281-258-1212 |
| INOP | 10678001 | HARDIN COUNTY WCID 1 - HARDIN COUNTY WCID 1 | | Hardin | | |
| INOP | 11844001 | FOREST GLEN INC - FOREST GLEN WWTF | They are laying new stabs for some of their units. It will take at least two week for they can place the tanks on the new stabs. The collection system is ok. They are trucking the wastewater to another wwtp for treatment. | Walker | Justin Perrit | 936-661-9013 |
| INOP | 11141001 | TRESCHWIG JOINT POWERS BOARD - TRESCHWIG CENTRAL WWTP | Plant is offline - flooded (unknown status) | Harris | Gregory Camp | 281-902-0966 |

WW INOP
Dataset 09.07.2017 1315hrs

| vvlCurrentStatus | ID | facilityName | comments_Second | county | Expr1 | Expr2 |
|------------------|----------|---|---|------------|-------------------|--------------|
| INOP | 13563001 | BEACH ROAD MUD - BEACH ROAD MUD WWTP | Tornado hit, the clarifier was hit by debris, draining system and trucking wastewater to Bay City, WWTP. The collection system is a vacuum system, the was damage, They are working on fixing the system | Matagorda | Emil Krejci | 979-429-7081 |
| INOP | 10495030 | CITY OF HOUSTON - WEST DISTRICT WWTP | The operational status of the WWTP and CS are unknown The facility is inaccessible due to high water. | Harris | | |
| INOP | 14564001 | FORT BEND COUNTY MUD 162 - FORT BEND COUNTY MUD 162 WWTP | The facility is flooded however the facility is still online. Facility cannot be assessed so the overall status is unknown. | Fort Bend | Michael Thornhill | 281-923-7214 |
| INOP | 13628001 | FORT BEND COUNTY MUNICIPAL UTILITY DISTRICT 112 - NEW TERRITORY NORTH REGIONAL WWTP | Plant appears to be online but is flooded. Unable to assess therefore overall status is unknown. | Fort Bend | Michael Thornhill | 281-923-7214 |
| INOP | 12088001 | US ARMY CORPS OF ENGINEERS - ROCKY CREEK PARK WWTP | Park is closed and no inflows to WWTP are occurring. WWTP has been turned off and is idle. Lift station is under water and extent of damage throughout system is unknown. Contact indicated would likely be the end of October before plant can be accessed | Washington | Randall McCartney | 979-596-1624 |
| INOP | 14205001 | LAMAR CISD - FOSTER BRISCO SCHOOL COMPLEX | WWTP is flooded and cannot be assessed, however facility is online. Overall staus is unknown. | Fort Bend | Michael Thornhill | 281-923-7214 |

WW INOP
Dataset 09.07.2017 1315hrs

| vvlCurrentStatus | ID | facilityName | comments_Second | county | Expr1 | Expr2 |
|------------------|----------|--|--|----------|----------------|--------------|
| INOP | 10312001 | CITY OF WEST COLUMBIA - CITY OF WEST COLUMBIA WWTP | The plant and lift stations are under water. They hop to due a full assessment on the system by Friday. | Brazoria | Terry Elliot | 979-481-3027 |
| INOP | 11061001 | GREENWOOD UTILITY DISTRICT - GREENWOOD UTILITY DISTRICT WWTP | Flooded generator has to be dried out before use. 2 offsite lifts are operable. The subscriber district parkway has seven lift stations that we do not have complete status updates on. Collection status NOCNSSO. Overflows system is underwater. | Harris | Susan Young | 281-258-1212 |
| INOP | 1006000 | CHEVRON PHILLIPS CEDAR BAYOU CHEMICAL PLANT | | HARRIS | Joseph A. Reza | 469-471-5898 |
| INOP | 11916001 | P C S DEVELOPMENT COMPANY - PARKVIEW SUBDIVISION WWTP | Chlorine room fell over, 1 ft water electrical pole fell over. System has no power | Orange | Chandra Hall | |
| INOP | 10108001 | CITY OF LIBERTY - CITY OF LIBERTY MAIN WWTP | The plant is currently under water. The city major and some of the minor lift stations are operatonal. It will be days before they will be able asset the plant. They are currently working on getting the minor lift stations up and running to get the sew | Liberty | Mark Reed | 936-661-3424 |
| INOP | 13804001 | TEXAS DEPARTMENT OF CRIMINAL JUSTICE - TERRELL WWTP | Prison has been evacuated and WWTP and other systems shut down. Personnel currently on-site at prison, WWTP is still flooded and not accessible. Resources are being dedicated to addressing potable water issues. | Brazoria | Tony Robinson | 936-355-2829 |

WW INOP
Dataset 09.07.2017 1315hrs

| vvlCurrentStatus | ID | facilityName | comments_Second | county | Expr1 | Expr2 |
|------------------|----------|---|--|-----------|----------------------|------------------|
| INOP | 11329001 | NEWPORT MUD - NEWPORT MUD WWTP | 39 Million gallons of water is covering the system. No Power. They are flooded. They are next to an 8foot levee San Jacinto River. They are trying to get their hands on pumps. They evacuated the plant. They are still in need of pumps. they have pumps but | Harris | Cullen Francis | 832-250- 8367 |
| INOP | 13245001 | GRAND LAKES MUD 4 - GRAND LAKES REGIONAL WWTP | System is innaccessible. System is underwater. | Fort Bend | Susan Young | 281-258- 1212 |
| INOP | 14578001 | BLOOMINGTON ISD - BLOOMINGTON JUNIOR HIGH AND HIGH SCHOOL WWTP | School has been cancelled unit 9/18/17. Power expected to be restored by 9/11/17 at which time an assessment of the WWTP can be accomplished. | Victoria | Misty Bansfield | 361-649- 6871 |
| INOP | 11713001 | CEDAR BAYOU PARK UTILITY DISTRICT - CEDAR BAYOU PARK WWTP | Finally able to access plant on 9/4/17 (by foot), bridge and road damage preventing vehicle access. Electrician expected on site 9/5/17 and insurance claims are underway. Entire service area evacuated, no inflow being received. Contact mentioned Ci | Harris | Jerald Landin | 713-818- 3602 |
| INOP | 11553001 | BLUE RIDGE WEST MUD - BLUE RIDGE WEST MUD WWTP | Operator stated that the area is flooded but it seems that the plant is okay. Plant is still online. Cannot assess plant so overall status is unknown. | Fort Bend | Michael Thornhill | 281-923- 7214 |
| INOP | 13839001 | MAURICEVILLE MUD - MAURICEVILLE WWTP | 3 lift stations are up, and One lift station is down. Many grinder pumps not working due to flooding. | Orange | Orland Williford | 409-745- 4882 |

WW INOP
Dataset 09.07.2017 1315hrs

| vvlCurrentStatus | ID | facilityName | comments_Second | county | Expr1 | Expr2 |
|------------------|----------|---|--|-----------|--------------------------|------------------|
| INOP | 14581001 | CITY OF BRAZORIA - CITY OF BRAZORIA WWTP | The plant and lift stations are under water. Have ask for a strike team to help get the back in working order for the Texxas City SOC. All electial system are under water they are hoping the they dry out the system and they work. They will need to rep | Brazoria | David Jordan | 979-798- 2489 |
| INOP | 11523001 | HARRIS COUNTY MUD 102 - HARRIS COUNTY MUD 102 WWTP | Disinfection. Collection is partial. Parts are underwater. | Harris | Susan Young | 281-258- 1212 |
| INOP | 13172002 | CINCO MUD 1 - CINCO RANCH SOUTH WWTP | Waiting on a status update on WWTP. Alot of information was unknown. | Fort Bend | James Wolfe | 281-740- 6540 |
| INOP | 4917000 | ARANSAS NATIONAL WILDLIFE REFUGE WATER PLANT | Facility contact was made but the system is still being assessed. The contact stated that he would call back Wednesday with an update. Please note the waste stream authorized for discharge is reverse osmosis reject water. | ARANSAS | Joe Seand | 361-349- 1139 |
| INOP | 10607003 | CITY OF ROSENBERG - CITY OF ROSENBERG WWTP 1A | Plant is flooded so the overall status is unknown hoeweever plant is still online. May have blower damage. | Fort Bend | Michael Thornhill | 281-740- 6540 |
| INOP | 11290001 | JACKRABBIT ROAD PUD - JACKRABBIT ROAD PUD WWTP | 5 ft of water in facility David Walker 8322501142 has more informtion on the plant 09/05/2017 - Called David Walker -Facility is still underwater, getting portable generator to operate lift station, and start chlorinating wastewater -Collection system | Harris | John Montgome ry | 281-217- 1031 |
| NonOp | 10495109 | CITY OF HOUSTON - TURKEY CREEK WWTP | The WWTP is inaccessible and plant status is Unknown | Harris | Walid Samarneh, PE | 832-395- 5771 |

WW INOP
Dataset 09.07.2017 1315hrs

| vvlCurrentStatus | ID | facilityName | comments_Second | county | Expr1 | Expr2 |
|------------------|----------|--|---|----------|----------------------|------------------|
| NonOp | 12113001 | ORBIT SYSTEMS INC - BEECHWOOD WWTP | Unable to see the facility. The POC is not the facility owner anymore. The condition of the damage is unknown. August 28, 5 to 7 days of not having access. A mandatory evacuation. A drainage ditch must be crossed to access the facility. There is only 1 co | Brazoria | Peggy Pual | 979-292- 5160 |
| NonOp | 10875001 | ORANGE COUNTY WCID 1 - OAK LANE WWTP | The facility is experieicing by pass. They have no power and he facity is not operational. There is not current disinfection | Orange | Norman Blackman | 409-880- 2710 |
| NonOp | 10495149 | CITY OF HOUSTON - FOREST COVE WWTP | The plant is underwater and currently not in operation. | Harris | Johnathan Dawson | 281-830- 9260 |
| NonOp | 394000 | ALCOA POINT COMFORT OPERATIONS | Kevin Riggs, Plant Manager, called to provide update, but Gary is the contact person. The plant is currently offline but the Storm Lake and lake system received 160 MG of stormwater during the hurricane to the already 75 MG prior to the event. Plant is st | CALHOUN | Gary Broughton | 361-646- 9620 |
| NonOp | 10495146 | CITY OF HOUSTON - KINGWOOD CENTRAL WWTP | Email from Walid S. on 9/6 stated that the WWTP was non-operational. No other details were provided. | Harris | Walid Samarneh | 713-501- 2782 |
| NonOp | 14724003 | BRAZORIA COUNTY MUD 55 - BRAZORIA COUNTY MUD 55 WWTP | Facility seems to be okay but the area is flooded. Facility is still online. Facility cannot be assessed so the overall status is unknown. | Brazoria | Michael Thornhill | 281-923- 7214 |
| NonOp | 447000 | UNION CARBIDE SEADRIFT PLANT | No Answer. | CALHOUN | John Yosko | 361-571- 8747 |

WW INOP
Dataset 09.07.2017 1315hrs

| vvlCurrentStatus | ID | facilityName | comments_Second | county | Expr1 | Expr2 |
|------------------|----------|--|---|--------------|-----------------|--------------|
| NonOp | 14218001 | ARCHDIOCESE OF GALVESTON HOUSTON - CIRCLE LAKE RETREAT CENTER WWTP | 4. No power 10. no power, not currently collecting 13. On generator within one day hopefully Phone number 281-356-6764 not functional possibly due to storm. | Montgomery | Gloria Bustillo | 281-900-7244 |
| NonOp | 3083000 | OCCIDENTAL CHEMICAL INGLESIDE PLANT | No answer from facility contact. Previous Assessment: WW treatment plant does not have power. AEP should be restoring power today. Sanitary plant is also down. No indication of overflows. Currently using retention at lift stations as there is no plant ope | SAN PATRICIO | Aron Bagget | 361-776-6395 |
| NonOp | 10932001 | HARRIS COUNTY - BEAR CREEK PIONEERS PARK WWTP | Plant is underwater. Unable to adeqautely assess. Did a drone fly over of the plant and it is flooded. The POC Stated: Control panels are currently underwater. Blowers motor needs to be replaced. Chlorine pumps need to be replaced. Chlorine drum is loo | Harris | Darrell Kelly | 281-910-0151 |
| 40 | Total | | | | | |